

PT. MITRA TIMUR LESTARI, HIGHPOINT (VECHO ACOUSTIC PANEL)

TEST REPORT

SCOPE OF WORK

100% POLYESTER FIBER ACOUSTIC PANEL

REPORT NUMBER

200421005SHF-001

TEST DATE(S)

2020-04-21 - 2020-04-27

ISSUE DATE

2020-04-27


PAGES

6

DOCUMENT CONTROL NUMBER

LFT-APAC-SHF-OP-10k(May 1, 2019)

© 2020 INTERTEK



Test Report

Statement

- 1.This report is invalid without company's special seal for testing on assigned page.
- 2.This report is invalid without authorized person's signature.
- 3.This report is invalid where any unauthorized modification indicated.
- 4.Don't copy this report in partial (except full copy) without any official approval in written by our company. This report is invalid without re-stamping the special seal for testing in copying report.
- 5.Any holder of this document is advised that this report is for the exclusive use of Intertek's Customer and is provided pursuant to the agreement between Intertek and its Customer. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. This report was made with due care within the limitation of a defined scope of work and on the basis of information, materials and instructions received from the Customer or its nominated third parties. Intertek is under no obligation to refer to or report upon any facts or circumstances which are outside the specific instructions received and accepts no responsibility to any parties whatsoever, following the issue of the report, for any matters arising outside the agreed scope of the works. The tests results are not intended to be a recommendation for any particular course of action. Customer is responsible for acting as it sees fit on the basis of such results.
- 6.Intertek's written consent is required to use Intertek's name or logo on the object, product or service being tested. The observations and test results in this report relate only to the sample under test. This report alone does not indicate that the item, product or service has passed any Intertek certification program.

Test Report

Issue Date : 2020-04-27 Intertek Report No. 200421005SHF-001
 Applicant : PT. Mitra Timur Lestari, HighPoint (VECHO Acoustic Panel)
 Address : Jalan Daan Mogot KM 12 no. 55, Jakarta 11730, Indonesia
 Attn. : Ms. Cindy Meilina
 Manufacturer : Produced Exclusively for PT. Mitra Timur Lestari
 Address : Zhangjiagang City, Jiangsu Province, China
 Test Type : Performance test, samples provided by the applicant.

Product Information

Product Name	100% POLYESTER FIBER ACOUSTIC PANEL	Brand	/
Sample Description	Good Condition	Sample Amount	5 pcs
		Received Date	2020-04-10
Sample ID	Model	Specification	
S200421005SHF.001	/	12mm	

Test Methods And Standards

Test Standard	ASTM C423-17
Specification Standard	ASTM C423-17
Test Conclusion	The samples were tested according to the above standards, and the results are shown in the following page.

Note:

1.This report relates specifically to the sample(s) that were drawn and provided by the applicant or their nominated third party. The reported result(s) provide no warranty or verification on the sample(s) representing any specific goods and/or shipment and only relate to the sample(s) as received and tested.

Report Authorized


 Name: Mason Wang
 Title: Reviewer


 Name: Jackie Zhou
 Title: Project Engineer



Test Report

Issue Date: 2020-04-27

Intertek Report No. 200421005SHF-001

Test Items, Method and Results:


Test Method: ASTM C423-17 Sound Absorption Coefficients

Volume of the reverberation room	Vs, m ³	240	Installation Type ¹ :	Type-A
Room temperature	t1, °C	17	t2, °C	17
Relative humidity of test rooms	H1,%	75	H2,%	75

Sample description:

Sample size (width*length),mm	2440*1220	Thickness, mm	12.0
Edge treatment	/	Mass, kg/m ²	2.30
Test Area, m ²	10.8		

Frequency (Hz)	αs
100	0.01
125	0.00
160	0.02
200	0.06
250	0.07
315	0.11
400	0.17
500	0.24
630	0.36
800	0.48
1000	0.57
1250	0.66
1600	0.72
2000	0.83
2500	0.88
3150	0.93
4000	1.04
5000	1.04
NRC	0.45
SAA	0.43



Note: 1. Installation type was defined in accordance with ASTM E795-16.

Test Report

Issue Date: 2020-04-27

Intertek Report No. 200421005SHF-001

Test Photos:



Test set up

Test Report

Issue Date: 2020-04-27

Intertek Report No. 200421005SHF-001

Appendix A: Sample Received Photo



Revision:

NO.	Date	Changes	Author	Reviewer
200421005SHF-001	2020-04-27	First issue	Mason Wang	Jackie Zhou